

Inspection Report

John Smith

Property Address:

1233 Applebury Drive Laurel MD 20716



Home Support Property Inspections

Earle Johnson MD 29961

Table of Contents

Cover Page	<u>1</u>
Table of Contents	3
Intro Page	4
1 Roofing	5
2 Exterior	8
3 Garage	9
4 Interiors	10
5 Structural Components	12
6 Plumbing System	
7 Electrical System	16
8 Heating System	18
9 Cooling System	
10 Insulation and Ventilation	22
11 Built-In Kitchen Appliances	23
General Summary	24

Date: 1/10/2019	Time: 03:38 PM	Report ID: 1111
Property: 1233 Applebury Drive Laurel MD 20716	Customer: John Smith	

Comment Key or Definitions

The following definitions of comment descriptions represent this inspection report. All comments by the inspector should be considered before purchasing this home. Any recommendations by the inspector to repair or replace suggests a second opinion or further inspection by a qualified contractor. All costs associated with further inspection fees and repair or replacement of item, component or unit should be considered before you purchase the property.

Inspected (IN) = I visually observed the item, component or unit and if no other comments were made then it appeared to be functioning as intended allowing for normal wear and tear.

Not Inspected (NI)= I did not inspect this item, component or unit and made no representations of whether or not it was functioning as intended and will state a reason for not inspecting.

Not Present (NP) = This item, component or unit is not in this home or building.

Repair or Replace (RR) = The item, component or unit is not functioning as intended, or needs further inspection by a qualified contractor. Items, components or units that can be repaired to satisfactory condition may not need replacement.

In Attendance:	Type of building:	Approximate age of building:
Customer and their agent	Single Family (2 story)	Over 25 Years
Temperature:	Weather:	Ground/Soil surface condition:
Below 65 (F) = 18 (C)	Clear	Dry
Rain in last 3 days:	Radon Test:	Water Test:
No	No	No

1. Roofing

The home inspector shall observe: Roof covering; Roof drainage systems; Flashings; Skylights, chimneys, and roof penetrations; and Signs of' leaks or abnormal condensation on building components. The home inspector shall: Describe the type of roof covering materials; and Report the methods used to observe the roofing. The home inspector is not required to: Walk on the roofing; or Observe attached accessories including but not limited to solar systems, antennae, and lightning arrestors.

Styles & Materials

	f Covering: 3-Tab fiberglass	Viewed roof covering from: Binoculars	Chimney (exterior): Vinyl siding				
				IN	NI	NP	RR
1.0	Roof Coverings						•
1.1	Flashings			•			
1.2	Skylights, Chimneys	and Roof Penetrations					•
1.3	Roof Drainage Syster	ns		•			
IN=	Inspected, NI= Not Inspe	cted, NP= Not Present, RR= Repair or Replace		IN	NI	NP	RR

Comments:

1.0 Based on a visual evaluation my educated guess is the roof is between 15- 20 years old and nearing the end of it's useful life expectancy. The standard life expectancy of asphalt shingles is 15-20 years





1.0 Item 1(Picture) Front roof

1.0 Item 2(Picture) Front roof



1.0 Item 3(Picture) Left side front gutter



1.0 Item 4(Picture) Right side front gutter





1.0 Item 5(Picture) Rear roof

1.0 Item 6(Picture) Rear roof





1.0 Item 7(Picture) Rear left side gutter

1.0 Item 8(Picture) Rear right side gutter

1.2 Repair or replace



1.2 Item 1(Picture) Rear chimney

The roof of the home was inspected and reported on with the above information. While the inspector makes every effort to find all areas of concern, some areas can go unnoticed. Roof coverings and skylights can appear to be leak proof during inspection and weather conditions. Our inspection makes an attempt to find a leak but sometimes cannot. Please be aware that the inspector has your best interest in mind. Any repair items mentioned in this report should be considered before purchase. It is recommended that qualified contractors be used in your further inspection or repair issues as it relates to the comments in this inspection report.

2. Exterior



The home inspector shall observe: Wall cladding, flashings, and trim; Entryway doors and a representative number of windows; Garage door operators; Decks, balconies, stoops, steps, areaways, porches and applicable railings; Eaves, soffits, and fascias; and Vegetation, grading, drainage, driveways, patios, walkways, and retaining walls with respect to their effect on the condition of the building. The home inspector shall: Describe wall cladding materials; Operate all entryway doors and a representative number of windows; Operate garage doors manually or by using permanently installed controls for any garage door operator; Report whether or not any garage door operator will automatically reverse or stop when meeting reasonable resistance during closing; and Probe exterior wood components where deterioration is suspected. The home inspector is not required to observe: Storm windows, storm doors, screening, shutters, awnings, and similar seasonal accessories; Fences; Presence of safety glazing in doors and windows; Garage door operator remote control transmitters; Geological conditions; Soil conditions; Recreational facilities (including spas, saunas, steam baths, swimming pools, tennis courts, playground equipment, and other exercise, entertainment, or athletic facilities); Detached buildings or structures; or Presence or condition of buried fuel storage tanks. The home inspector is not required to: Move personal items, panels, furniture, equipment, plant life, soil, snow, ice or debris that obstructs access or visibility.

Styles & Materials


	Siding Material: Exterior Entry Doors: [Vinyl Fiberglass		iveway: Asphalt		
		IN	NI	NP	RR
2.0	Wall Cladding Flashing and Trim	•			
2.1	Doors (Exterior)	•			
2.2	Windows	•			
2.3	Decks, Balconies, Stoops, Steps, Areaways, Porches, Patio/Cover and Applicable Railings	•			
2.4	Vegetation, Grading, Drainage, Driveways, Patio Floor, Walkways and Retaining Walls (With respect to their effect on the condition of the building)	1			•
2.5	Eaves, Soffits and Fascias	•			

IN= Inspected, NI= Not Inspected, NP= Not Present, RR= Repair or Replace

IN NI NP RR

Comments:

2.4 Repair or replace



2.4 Item 1(Picture) Rear of home

The exterior of the home was inspected and reported on with the above information. While the inspector makes every effort to find all areas of concern, some areas can go unnoticed. Please be aware that the inspector has your best interest in mind. Any repair items mentioned in this report should be considered before purchase. It is recommended that qualified contractors be used in your further inspection or repair issues as it relates to the comments in this inspection report.

IN NI NP RR

3. Garage

Styles & Materials

Gar	Garage Door Type: Garage Door Material: Auto-opener Manufacturer:						
(One manual	Fiberglass	ALLISTER				
				IN	NI	NP	RR
3.0	Garage Ceilings			•			
3.1	Garage Walls (including	Firewall Separation)		•			
3.2	Garage Floor			•			
3.3	Garage Door (s)			•			
3.4	Occupant Door (from g	arage to inside of home)		•			
3.5	Garage Door Operators	(Report whether or not doors will rev	erse when met with resistance)	•			

IN= Inspected, NI= Not Inspected, NP= Not Present, RR= Repair or Replace

Comments:

4. Interiors

The home inspector shall observe: Walls, ceiling, and floors; Steps, stairways, balconies, and railings; Counters and a representative number of installed cabinets; and A representative number of doors and windows. The home inspector shall: Operate a representative number of windows and interior doors; and Report signs of abnormal or harmful water penetration into the building or signs of abnormal or harmful condensation on building components. The home inspector is not required to observe: Paint, wallpaper, and other finish treatments on the interior walls, ceilings, and floors; Carpeting; or Draperies, blinds, or other window treatments.

Styles & Materials

Ceiling Materials: Wall Material: Floor Covering(s):

Gypsum Board Gypsum Board Carpet

Hardwood T&G

Interior Doors: Window Types: Window Manufacturer:

Hollow core Double-hung CRESTLINE

Cabinetry: Countertop: Wood Granite

		IN	NI	NP	_RR_
4.0	Ceilings				•
4.1	Walls				•
4.2	Floors	•			
4.3	Steps, Stairways, Balconies and Railings	•			
4.4	Counters and Cabinets (representative number)	•			
4.5	Doors (representative number)	•			
4.6	Windows (representative number)	•			


IN= Inspected, NI= Not Inspected, NP= Not Present, RR= Repair or Replace


IN NI NP RR

Comments:

4.0 Repair or replace








4.0 Item 2(Picture)


4.1 Repair or replace





4.1 Item 1(Picture)

4.1 Item 2(Picture)



4.1 Item 3(Picture)

4.1 Item 4(Picture)

The interior of the home was inspected and reported on with the above information. While the inspector makes every effort to find all areas of concern, some areas can go unnoticed. The inspection did not involve moving furniture and inspecting behind furniture, area rugs or areas obstructed from view. Please be aware that the inspector has your best interest in mind. Any repair items mentioned in this report should be considered before purchase. It is recommended that qualified contractors be used in your further inspection or repair issues as it relates to the comments in this inspection report.

5. Structural Components

The Home Inspector shall observe structural components including foundations, floors, walls, columns or piers, ceilings and roof. The home inspector shall describe the type of Foundation, floor structure, wall structure, columns or piers, ceiling structure, roof structure. The home inspector shall: Probe structural components where deterioration is suspected; Enter under floor crawl spaces, basements, and attic spaces except when access is obstructed, when entry could damage the property, or when dangerous or adverse situations are suspected; Report the methods used to observe under floor crawl spaces and attics; and Report signs of abnormal or harmful water penetration into the building or signs of abnormal or harmful condensation on building components. The home inspector is not required to: Enter any area or perform any procedure that may damage the property or its components or be dangerous to or adversely effect the health of the home inspector or other persons.

Styles & Materials

Foundation: Roof Structure: Roof-Type:

Poured concrete Engineered wood trusses Gable

Method used to observe attic: Attic info:

From entry

Light in attic

No Storage

		IN	NI	NP	RR
5.0	Foundations, Basement and Crawlspace (Report signs of abnormal or harmful water penetration into the building or signs of abnormal or harmful condensation on building components.)	•			
5.5	Roof Structure and Attic				•

IN= Inspected, NI= Not Inspected, NP= Not Present, RR= Repair or Replace

IN NI NP RE

Comments:

5.5 Repair or replace





5.5 Item 1(Picture)

5.5 Item 2(Picture)

The structure of the home was inspected and reported on with the above information. While the inspector makes every effort to find all areas of concern, some areas can go unnoticed. Please be aware that the inspector has your best interest in mind. Any repair items mentioned in this report should be considered before purchase. It is recommended that qualified contractors be used in your further inspection or repair issues as it relates to the comments in this inspection report.

6. Plumbing System

The home inspector shall observe: Interior water supply and distribution system, including: piping materials, supports, and insulation; fixtures and faucets; functional flow; leaks; and cross connections; Interior drain, waste, and vent system, including: traps; drain, waste, and vent piping; piping supports and pipe insulation; leaks; and functional drainage; Hot water systems including: water heating equipment; normal operating controls; automatic safety controls; and chimneys, flues, and vents; Fuel storage and distribution systems including: interior fuel storage equipment, supply piping, venting, and supports; leaks; and Sump pumps. The home inspector shall describe: Water supply and distribution piping materials; Drain, waste, and vent piping materials; Water heating equipment; and Location of main water supply shutoff device. The home inspector shall operate all plumbing fixtures, including their faucets and all exterior faucets attached to the house, except where the flow end of the faucet is connected to an appliance. The home inspector is not required to: State the effectiveness of anti-siphon devices; Determine whether water supply and waste disposal systems are public or private; Operate automatic safety controls; Operate any valve except water closet flush valves, fixture faucets, and hose faucets; Observe: Water conditioning systems; Fire and lawn sprinkler systems; On-site water supply quantity and quality; On-site waste disposal systems; Foundation irrigation systems; Spas, except as to functional flow and functional drainage; Swimming pools; Solar water heating equipment; or Observe the system for proper sizing, design, or use of proper materials.

Styles & Materials

Water Source: Plumbing Water Supply (into

Public **home):**

Copper

Plumbing Waste: Water Heater Power Source:

PVC Gas (quick recovery)

Manufacturer: Water Heater Location:

BRADFORD-WHITE Utility Room

Water Heater Estimated

Age:

2018 Beginning of service

life

Plumbing	Water	Distribution	(inside
----------	-------	--------------	---------

home):

Copper

Water Heater Capacity:

50 Gallon (2-3 people)

Water Pressure:

80 PSI

		IN	NI	NP	RR
6.0	Plumbing Drain, Waste and Vent Systems	•			
6.1	Plumbing Water Supply, Distribution System and Fixtures	•			
6.2	Hot Water Systems, Controls, Chimneys, Flues and Vents	•			
6.3	Main Water Shut-off Device (Describe location)	•			
6.4	Fuel Storage and Distribution Systems (Interior fuel storage, piping, venting, supports, leaks)	•			
6.5	Main Fuel Shut-off (Describe Location)	•			
6.6	Sump Pump	•			

IN= Inspected, NI= Not Inspected, NP= Not Present, RR= Repair or Replace

IN NI NP RR

Comments:

6.2 Satisfactory




6.2 Item 1(Picture)

6.3 Satisfactory



6.3 Item 1(Picture) Garage

6.5 Satisfactory



6.5 Item 1(Picture) Garage

Home Support Property Inspections

Smith

The plumbing in the home was inspected and reported on with the above information. While the inspector makes every effort to find all areas of concern, some areas can go unnoticed. Washing machine drain line for example cannot be checked for leaks or the ability to handle the volume during drain cycle. Older homes with galvanized supply lines or cast iron drain lines can be obstructed and barely working during an inspection but then fails under heavy use. If the water is turned off or not used for periods of time (like a vacant home waiting for closing) rust or deposits within the pipes can further clog the piping system. Please be aware that the inspector has your best interest in mind. Any repair items mentioned in this report should be considered before purchase. It is recommended that qualified contractors be used in your further inspection or repair issues as it relates to the comments in this inspection report.

7. Electrical System

The home inspector shall observe: Service entrance conductors; Service equipment, grounding equipment, main over current device, and main and distribution panels; Amperage and voltage ratings of the service; Branch circuit conductors, their over current devices, and the compatibility of their ampacities and voltages; The operation of a representative number of installed ceiling fans, lighting fixtures, switches and receptacles located inside the house, garage, and on the dwelling's exterior walls; The polarity and grounding of all receptacles within six feet of interior plumbing fixtures, and all receptacles in the garage or carport, and on the exterior of inspected structures; The operation of ground fault circuit interrupters; and Smoke detectors. The home inspector shall describe: Service amperage and voltage; Service entry conductor materials; Service type as being overhead or underground; and Location of main and distribution panels. The home inspector shall report any observed aluminum branch circuit wiring. The home inspector shall report on presence or absence of smoke detectors, and operate their test function, if accessible, except when detectors are part of a central system. The home inspector is not required to: Insert any tool, probe, or testing device inside the panels; Test or operate any over current device except ground fault circuit interrupters; Dismantle any electrical device or control other than to remove the covers of the main and auxiliary distribution panels; or Observe: Low voltage systems; Security system devices, heat detectors, or carbon monoxide detectors; Telephone, security, cable TV, intercoms, or other ancillary wiring that is not a part of the primary electrical distribution system; or Builtin vacuum equipment.

Styles & Materials

Electrical Service Conductors: Panel capacity: Panel Type:

Below ground 200 AMP Circuit breakers

Electric Panel Manufacturer: Branch wire 15 and 20 AMP: Wiring Methods:

CHALLENGER Copper Romex

		IN	NI	NP	RR
7.0	Service Entrance Conductors	•			
7.1	Service and Grounding Equipment, Main Overcurrent Device, Main and Distribution Panels	•			
7.2	Branch Circuit Conductors, Overcurrent Devices and Compatability of their Amperage and Voltage	•			
7.3	Connected Devices and Fixtures (Observed from a representative number operation of ceiling fans, lighting fixtures, switches and receptacles located inside the house, garage, and on the dwelling's exterior walls)	•			
7.4	Polarity and Grounding of Receptacles within 6 feet of interior plumbing fixtures, all receptacles in garage, carport and exterior walls of inspected structure	•			
7.5	Operation of GFCI (Ground Fault Circuit Interrupters)	•			
7.6	Location of Main and Distribution Panels	•			
7.7	Smoke Detectors	•			
7.8	Carbon Monoxide Detectors	•			


IN= Inspected, NI= Not Inspected, NP= Not Present, RR= Repair or Replace

Comments:

NI NP RR

7.6 Satisfactory





7.6 Item 1(Picture) Basement rec room

7.6 Item 2(Picture) Basement rec room

The electrical system of the home was inspected and reported on with the above information. While the inspector makes every effort to find all areas of concern, some areas can go unnoticed. Outlets were not removed and the inspection was only visual. Any outlet not accessible (behind the refrigerator for example) was not inspected or accessible. Please be aware that the inspector has your best interest in mind. Any repair items mentioned in this report should be considered before purchase. It is recommended that qualified contractors be used in your further inspection or repair issues as it relates to the comments in this inspection report.

8. Heating System

The home inspector shall observe permanently installed heating and cooling systems including: Heating equipment; Cooling Equipment that is central to home; Normal operating controls; Automatic safety controls; Chimneys, flues, and vents, where readily visible; Solid fuel heating devices; Heat distribution systems including fans, pumps, ducts and piping, with supports, insulation, air filters, registers, radiators, fan coil units, convectors; and the presence of an installed heat source in each room. The home inspector shall describe: Energy source; and Heating equipment and distribution type. The home inspector shall operate the systems using normal operating controls. The home inspector shall open readily openable access panels provided by the manufacturer or installer for routine homeowner maintenance. The home inspector is not required to: Operate heating systems when weather conditions or other circumstances may cause equipment damage; Operate automatic safety controls; Ignite or extinguish solid fuel fires; or Observe: The interior of flues; Fireplace insert flue connections; Humidifiers; Electronic air filters; or The uniformity or adequacy of heat supply to the various rooms.

Styles & Materials

Heat Type: Energy Source: Number of Heat Systems (excluding wood):

Heat Pump Forced Air (also provides cool air) Gas Two

Heat System Brand:Filter Type:Filter Size:GOODMANDisposable16x20

Types of Fireplaces: Operable Fireplaces: Estimated Age:

Conventional One 2016 (2 Years) Beginning of service life


		IN	NI	NP	RR
8.0	Heating Equipment	•			
8.1	Normal Operating Controls	•			
8.2	Automatic Safety Controls	•			
8.3	Distribution Systems (including fans, pumps, ducts and piping, with supports, insulation, air filters, registers, radiators, fan coil units and convectors)	•			
8.4	Presence of Installed Heat Source in Each Room	•			
8.5	Chimneys, Flues and Vents (for fireplaces, gas water heaters or heat systems)	•			
8.6	Solid Fuel Heating Devices (Fireplaces, Woodstove)	•			
8.7	Gas/LP Firelogs and Fireplaces	•			

IN= Inspected, NI= Not Inspected, NP= Not Present, RR= Repair or Replace

Comments:

NI NP RR

8.0 Satisfactory




8.0 Item 1(Picture) Garage




8.0 Item 2(Picture) Garage

8.1 Satisfactory



8.1 Item 1(Picture) Hallway



8.1 Item 2(Picture)

The heating and cooling system of this home was inspected and reported on with the above information. While the inspector makes every effort to find all areas of concern, some areas can go unnoticed. The inspection is not meant to be technically exhaustive. The inspection does not involve removal and inspection behind service door or dismantling that would otherwise reveal something only a licensed heat contractor would discover. Please be aware that the inspector has your best interest in mind. Any repair items mentioned in this report should be considered before purchase. It is recommended that qualified contractors be used in your further inspection or repair issues as it relates to the comments in this inspection report.

9. Cooling System

The home inspector shall observe permanently installed heating and cooling systems including: Heating equipment; Cooling Equipment that is central to home; Normal operating controls; Automatic safety controls; Chimneys, flues, and vents, where readily visible; Solid fuel heating devices; Heat distribution systems including fans, pumps, ducts and piping, with supports, insulation, air filters, registers, radiators, fan coil units, convectors; and the presence of an installed heat source in each room. The home inspector shall describe: Energy source; and Heating equipment and distribution type. The home inspector shall operate the systems using normal operating controls. The home inspector shall open readily openable access panels provided by the manufacturer or installer for routine homeowner maintenance. The home inspector is not required to: Operate heating systems when weather conditions or other circumstances may cause equipment damage; Operate automatic safety controls; Ignite or extinguish solid fuel fires; or Observe: The interior of flues; Fireplace insert flue connections; Humidifiers; Electronic air filters; or The uniformity or adequacy of heat supply to the various rooms.

Styles & Materials

Cooling Equipment Type:

Heat Pump Forced Air (also provides warm air)

Estimated Age:

Electricity

2016 (2 Years) Beginning of service life

Cooling Equipment Energy Source:

Number of AC Only Units:

One

		IN	NI	NP	RR
9.2	Automatic Safety Controls	•			
9.8	Cooling and Air Handler Equipment	•			
9.9	Normal Operating Controls		•		
9.10	Presence of Installed Cooling Source in Each Room		•		
INI— In	enacted NI= Not Inspected NIP- Not Procent RIP- Repair or Poplace	INI	-NII	ND	DD

IN= Inspected, NI= Not Inspected, NP= Not Present, RR= Repair or Replace

IN NI NP RR


Central Air

Manufacturer:GOODMAN

Comments:

9.8 Satisfactory





9.8 Item 1(Picture) Rear exterior

9.8 Item 2(Picture)

9.9 To avoid unnecessary stress on the system, the cooling system was not tested because the heating system was operating

Home Support Property Inspections

Smith

The heating and cooling system of this home was inspected and reported on with the above information. While the inspector makes every effort to find all areas of concern, some areas can go unnoticed. The inspection is not meant to be technically exhaustive. The inspection does not involve removal and inspection behind service door or dismantling that would otherwise reveal something only a licensed heat contractor would discover. Please be aware that the inspector has your best interest in mind. Any repair items mentioned in this report should be considered before purchase. It is recommended that qualified contractors be used in your further inspection or repair issues as it relates to the comments in this inspection report.

10. Insulation and Ventilation

The home inspector shall observe: Insulation and vapor retarders in unfinished spaces; Ventilation of attics and foundation areas; Kitchen, bathroom, and laundry venting systems; and the operation of any readily accessible attic ventilation fan, and, when temperature permits, the operation of any readily accessible thermostatic control. The home inspector shall describe: Insulation in unfinished spaces; and Absence of insulation in unfinished space at conditioned surfaces. The home inspector shall: Move insulation where readily visible evidence indicates the need to do so; and Move insulation where chimneys penetrate roofs, where plumbing drain/ waste pipes penetrate floors, adjacent to earth filled stoops or porches, and at exterior doors. The home inspector is not required to report on: Concealed insulation and vapor retarders; or Venting equipment that is integral with household appliances.

Styles & Materials

Attic Insulation: Ventilation: **Exhaust Fans:**

Blown Gable vents Fan only

Dryer Power Source: Dryer Vent: 220 Electric Flexible Vinyl

		IN	NI	NP	RR
10.0	Insulation in Attic	•			
10.3	Ventilation of Attic and Foundation Areas	•			
10.4	Venting Systems (Kitchens, Baths and Laundry)	•			
10.5	Ventilation Fans and Thermostatic Controls in Attic	•			
IN= Inspected, NI= Not Inspected, NP= Not Present, RR= Repair or Replace		IN	NI	NP	RR

IN= Inspected, NI= Not Inspected, NP= Not Present, RR= Repair or Replace

Comments:

10.0 As is typical of homes of this age and construction, insulation levels are relatively modest. Upgrading insulation levels in a home is an improvement rather than a necessary repair



10.0 Item 1(Picture) Attic insulation level

The insulation and ventilation of the home was inspected and reported on with the above information. While the inspector makes every effort to find all areas of concern, some areas can go unnoticed. Venting of exhaust fans or clothes dryer cannot be fully inspected and bends or obstructions can occur without being accessible or visible (behind wall and ceiling coverings). Only insulation that is visible was inspected. Please be aware that the inspector has your best interest in mind. Any repair items mentioned in this report should be considered before purchase. It is recommended that qualified contractors be used in your further inspection or repair issues as it relates to the comments in this inspection report.

11. Built-In Kitchen Appliances

The home inspector shall observe and operate the basic functions of the following kitchen appliances: Permanently installed dishwasher, through its normal cycle; Range, cook top, and permanently installed oven; Trash compactor; Garbage disposal; Ventilation equipment or range hood; and Permanently installed microwave oven. The home inspector is not required to observe: Clocks, timers, self-cleaning oven function, or thermostats for calibration or automatic operation; Non built-in appliances; or Refrigeration units. The home inspector is not required to operate: Appliances in use; or Any appliance that is shut down or otherwise inoperable.

Styles & Materials

Dishwasher Brand: Disposer Brand: Exhaust/Range hood:

KENMORE BADGER KENMORE

Range/Oven: Built in Microwave:

KENMORE KENMORE

		IN	NI	NP	RR
11.0	Dishwasher	•			
11.1	Ranges/Ovens/Cooktops				•
11.2	Range Hood (s)	•			
11.3	Refrigerator	•			
11.4	Food Waste Disposer	•			
11.5	Microwave Cooking Equipment	٠			

IN= Inspected, NI= Not Inspected, NP= Not Present, RR= Repair or Replace

IN NI NP RR

Comments:

11.1 Repair or replace



11.1 Item 1(Picture)

The built-in appliances of the home were inspected and reported on with the above information. While the inspector makes every effort to find all areas of concern, some areas can go unnoticed. Please be aware that the inspector has your best interest in mind. Any repair items mentioned in this report should be considered before purchase. It is recommended that qualified contractors be used in your further inspection or repair issues as it relates to the comments in this inspection report.

General Summary



Home Support Property Inspections

Customer John Smith

Address

1233 Applebury Drive Laurel MD 20716

The following items or discoveries indicate that these systems or components **do not function as intended** or **adversely affects the habitability of the dwelling;** or **warrants further investigation by a specialist,** or **requires subsequent observation.** This summary shall not contain recommendations for routine upkeep of a system or component to keep it in proper functioning condition or recommendations to upgrade or enhance the function or efficiency of the home. This Summary is not the entire report. The complete report may include additional information of concern to the customer. It is recommended that the customer read the complete report.

1. Roofing

1.0 Roof Coverings

Repair or Replace

Based on a visual evaluation my educated guess is the roof is between 15- 20 years old and nearing the end of it's useful life expectancy. The standard life expectancy of asphalt shingles is 15-20 years

1. Roofing





1.0 Item 1(Picture) Front roof

1.0 Item 2(Picture) Front roof



1.0 Item 3(Picture) Left side front gutter



1.0 Item 4(Picture) Right side front gutter

1. Roofing



1.0 Item 5(Picture) Rear roof



1.0 Item 6(Picture) Rear roof



1.0 Item 7(Picture) Rear left side gutter



1.0 Item 8(Picture) Rear right side gutter

1.2 Skylights, Chimneys and Roof Penetrations Repair or Replace

Repair or replace



1.2 Item 1(Picture) Rear chimney

2. Exterior



2.4 Vegetation, Grading, Drainage, Driveways, Patio Floor, Walkways and Retaining Walls (With respect to their effect on the condition of the building)

Repair or Replace

Repair or replace




2.4 Item 1(Picture) Rear of home

4. Interiors


4.0 Ceilings

Repair or Replace

Repair or replace



4.0 Item 1(Picture)



4.0 Item 2(Picture)

4.1 Walls

Repair or Replace

Repair or replace

4. Interiors



Moisture observed with an infrared camera


FILE

76.3

4.1 Item 1(Picture)

Moisture observed

4.1 Item 2(Picture)



4.1 Item 3(Picture)

4.1 Item 4(Picture)


5. Structural Components

5.5 Roof Structure and Attic Repair or Replace

Repair or replace

5. Structural Components





5.5 Item 1(Picture)


5.5 Item 2(Picture)

11. Built-In Kitchen Appliances

11.1 Ranges/Ovens/Cooktops

Repair or Replace

Repair or replace



11.1 Item 1(Picture)

Home inspectors are not required to report on the following: Life expectancy of any component or system; The causes of the need for a repair; The methods, materials, and costs of corrections; The suitability of the property for any specialized use; Compliance or non-compliance with codes, ordinances, statutes, regulatory requirements or restrictions; The market value of the property or its marketability; The advisability or inadvisability of purchase of the property; Any component or system that was not observed; The presence or absence of pests such as wood damaging organisms, rodents, or insects; or Cosmetic items, underground items, or items not permanently installed. Home inspectors are not required to: Offer warranties or guarantees of any kind; Calculate the strength, adequacy, or efficiency of any system or component; Enter any area or perform any procedure that may damage the property or its components or be dangerous to the home inspector or other persons; Operate any system or component that is shut down or otherwise inoperable; Operate any system or component that does not respond to normal operating controls; Disturb insulation, move personal items, panels, furniture, equipment, plant life, soil, snow, ice, or debris that

obstructs access or visibility; Determine the presence or absence of any suspected adverse environmental condition or hazardous substance, including but not limited to mold, toxins, carcinogens, noise, contaminants in the building or in soil, water, and air; Determine the effectiveness of any system installed to control or remove suspected hazardous substances; Predict future condition, including but not limited to failure of components; Since this report is provided for the specific benefit of the customer(s), secondary readers of this information should hire a licensed inspector to perform an inspection to meet their specific needs and to obtain current information concerning this property.

Prepared Using HomeGauge http://www.HomeGauge.com : Licensed To Earle Johnson